



Test Report Summary

| Product Information | |
|--|--|
| Licence Number: | 215474 |
| Licensee: | ACOME |
| Product Identification | THERMOSTAT RADIO BIDIRECTIONNEL 523432 |
| Test Specifications | |
| Tested Application: | Water Floor Heating Systems |
| Temperature Sensor | |
| - Type: | NTC 100k |
| - Time Constant: | 4 Mins |
| Actuator Identification | 523235 |
| - Type: | Thermal: 2P |
| Valve Identification | THERMACOME |
| - Characteristic | 2-way/3-way valve: linear |
| AV Acronym | |
| Fan Speed (For Fan Coil Applications) | |
| - Characteristic | None |
| Test Result | |
| Temperature Control Accuracy C_A according EN 15500 | 0.5 |

30 July 2015

Brussels

A handwritten signature in black ink, appearing to read 'Peter Hug'.

Managing Director Dr. Peter Hug

eu.bac